## Autonics

- Observe all 'Safety Considerations' for safe and proper operation to avoid hazards.
- $\underline{\Lambda}$  symbol indicates caution due to special circumstances in which hazards may occur.
- **Warning** Failure to follow instructions may result in serious injury or death.
- Rectangular Inductive Proximity Sensors (□ 8/12/50 mm)



# **PS Series (DC 3-wire)** PRODUCT MANUAL

# For your safety, read and follow the considerations written in the instruction manual, other manuals and Autonics website.

The specifications, dimensions, etc. are subject to change without notice for product improvement. Some models may be discontinued without notice.

### Features

- Alternate frequency models allow adjacent installation of multiple sensors without interference (PSN17-□-F model)
- Operation indicator (red LED)
- IP67 protection structure (IEC standard)

- 01. Fail-safe device must be installed when using the unit with machinery that may cause serious injury or substantial economic loss. (e.g. nuclear power control, medical equipment, ships, vehicles, railways, aircraft, combustion apparatus, safety equipment, crime/disaster prevention devices, etc.) Failure to follow this instruction may result in personal injury, economic loss or fire.
- 02. Do not use the unit in the place where flammable/explosive/corrosive gas, high humidity, direct sunlight, radiant heat, vibration, impact, or salinity may be present.
- Failure to follow this instruction may result in explosion or fire. **03. Do not disassemble or modify the unit.**
- Failure to follow this instruction may result in fire. 04. Do not connect, repair, or inspect the unit while connected to a power source.
- Failure to follow this instruction may result in fire. **05. Check 'Connections' before wiring.**
- Failure to follow this instruction may result in fire.

**Caution** Failure to follow instructions may result in injury or product damage.

- 01. Use the unit within the rated specifications.
- Failure to follow this instruction may result in fire or product damage. **02. Use a dry cloth to clean the unit, and do not use water or organic solvent.** Failure to follow this instruction may result in fire.

#### **Cautions during Use**

**Safety Considerations** 

- Follow instructions in 'Cautions during Use'.
- Otherwise, it may cause unexpected accidents.
- 12 24 VDC== power supply should be insulated and limited voltage/current or Class 2, SELV power supply device.
- Use the product, after 0.8 sec of supplying power.
- Wire as short as possible and keep away from high voltage lines or power lines, to prevent surge and inductive noise.
- Do not use near the equipment which generates strong magnetic force or high frequency noise (transceiver, etc.).
- In case installing the product near the equipment which generates strong surge (motor, welding machine, etc.), use diode or varistor to remove surge.
- This unit may be used in the following environments.
  Indoors (in the environment condition rated in 'Specifications')|
- Altitude max. 2,000 m
- Pollution Degree 2
- Installation Category II

#### **Cautions for Installation**

- Install the unit correctly with the usage environment, location, and the designated specifications.
- Do NOT impacts with a hard object or excessive bending of the wire lead-out. It may cause damage the water resistance.
- Do NOT pull the Ø 2.5 mm cable with a tensile strength of 20 N, the Ø 4 mm cable with a tensile strength of 30 N or over and the Ø 5 mm cable with a tensile strength of 50 N or over. It may result in fire due to the broken wire.
- When extending wire, use AWG 22 cable or over within 200 m.

•	Refer to the table below for the screw tightening torque when mounting the bracket						
	Sensing side length	8 mm	12 mm	50 mm			

e chief in generation	•		
Tightening torque	0.7 N m	0.49 N m	0.98 N m

#### **Ordering Information**

This is only for reference, the actual product does not support all combinations. For selecting the specified model, follow the Autonics website.


PS	0	-	0	D	3	• •	
-	<b>ising sid</b> er: Side I	0		(unit: I	mm)	Control output  N: NPN Normally Open  N2: NPN Normally Closed  P: PNP Normally Open  P2: PNP Normally Closed	
-	<b>ising dis</b> er: Sensi		ance (ui	nit: mn	n)	• Sensing side No-mark: Standard type U: Upper side type	


## **Product Components**

Sensing side length	8 mm	12 mm	50 mm
Bracket	$1 \times$	$1 \times$	-
Bolt	M3 × 1	M3 × 2	$M4 \times 4$
Nut	$M3 \times 1$	M3 × 2	-
Spring washer	1 ×	-	-
Flat washer	1 ×	-	-


### Connections


## Cable type





Control Output Circuit (NPN output)





01) Sensing side length 8 mm: except zener diode

## **Operation Timing Chart**

		Normally Open	Normally Closed
Sensing target		Presence	Presence
		Nothing L L	Nothing Nothing
Load		Operation	Operation
Loud		Return L L	Return
Output			
voltage	PNP output		
Operatio	on indicator	ON C	
(red)		OFF L	

Installation	Standard type / U	Standard type / Upper side type			
Model	PS08-2.5D	PS12-4D	PS50-30D		
Sensing side length	8 mm	12 mm	50 mm		
Sensing distance	2.5 mm	4 mm	30 mm		
Setting distance	0 to 1.75 mm 0 to 2.8 mm 0 to 21 mm				
Hysteresis	$\leq$ 10 % of sensing	distance (sensing side l	ength 8 mm $\leq 20 \%$		
Standard sensing target: iron	$8 \times 8 \times 1$ mm	$12 \times 12 \times 1$ mm	$90 \times 90 \times 1 \text{ mm}$		
Response frequency <sup>01</sup>	1 kHz	500 Hz	50 Hz		
Affection by temperature	$\leq \pm$ 10 % for sensitive (sensing side length	ng distance at ambient 8 mm: $\leq \pm$ 15 %)	temperature 20 °C		
Indicator	Operating indicator	(red)			
Approval	C€ERE	C€ERE	C€ERE		
Unit weight (package)	$\approx$ 16 g ( $\approx$ 30 g)	$\approx$ 62 g ( $\approx$ 77 g)	≈ 220 g (≈ 256 g)		
01) The response frequency is 2 times of the standard se	s the average value. The sta ensing target, 1/2 of the ser	the average value. The standard sensing target is used and the width is set as nsing target, 1/2 of the sensing distance for the distance.			
Power supply	12 - 24 VDC== (ripple	P-P: $\leq$ 10 %), operating	g voltage: 10 - 30 VDC		
<b>Current consumption</b>	$\leq$ 10 mA				
Control output	Sensing side length 8 mm: $\leq$ 100 mA Sensing side length 12 mm, 50 mm: $\leq$ 200 mA				
Residual voltage	Sensing side length 8 mm: $\leq 1.0$ V Sensing side length 12 mm, 50 mm: $\leq 1.5$ V Surge protection circuit, output short over current protection circu reverse polarity protection				
Protection circuit					
Insulation resistance	$\geq 50~\text{M}\Omega$ (500 VDC=	negger)			
Dielectric strength	Between all terminals and case: 1,500 VAC $\sim 50$ / 60Hz for 1 minute (sensing side length 8 mm - between all terminals and case: 1,000 VAC $\sim 50$ / 60Hz for 1 minute				
Vibration	1 mm double amplitude at frequency 10 to 55 Hz in each of X, Y, Z directions for 2 hours				
Shock	500 m/s² ( $\approx$ 50 G) X, $^{\rm v}$	, Z directions for 3 time	es		
Ambient temp.	-25 to 70 %RH, storag	e: -30 to 80 %RH (no fre	eezing or condensatio		
Ambient humi.	35 to 95 %RH, storage	: 35 to 95 %RH (no free	zing or condensation		
Protection rating	IP67 (IEC standards)				
Connection	Cable type				
Cable spec.	Sensing side length 8 mm: Ø 2.5 mm, 3-wire, 1 m Sensing side length 12 mm: Ø 4 mm, 3-wire, 2 m Sensing side length 50 mm: Ø 5 mm, 3-wire, 2 m				
Wire spec.	Ø 2.5 mm cable : AWG 28 (0.08 mm, 19-core), insulator diameter: Ø 0.9 mm Ø 4 mm, Ø 5 mm cable : AWG 22 (0.08 mm, 60-core), insulator diameter: Ø 1.25 mm				
Material	Sensing side length 8 mm Case: PC, Sensing side length 12 mm Case: Heat-resistant ABS, Sensing side length 50 mm Case: PBT, standard cable (black): polyvinyl chloride (PVC)				

#### Dimensions

• Unit: mm, For the detailed dimensions of the product, follow the Autonics web site. A Operation indicator (red) B Tap hole

#### PS08


∞ 4 ♦

• Bracket

₽₫


22


Standard type













T 










**Setting Distance Formula** 

Detecting distance can be changed by the shape, size or material of the target. For stable sensing, intall the unit within the 70 % of sensing distance.

= Sensing distance (Sn) × 70 %



#### Mutual-interference & Influence by Surrounding Metals

#### Mutual-interference

Setting distance (Sa)

When plural proximity sensors are mounted in a close row, malfunction of sensor may be caused due to mutual interference.

Standard type

Therefore, be sure to provide a minimum distance between the two sensors, as below table.



[Face to Face]

ų




#### Influence by surrounding metals

When sensors are mounted on metallic panel, it must be prevented sensors from being affected by any metallic object except target. Therefore, be sure to provide a minimum distance as below chart.


• Standard type







(unit: mm)

Sensing side length Item	8 mm	12 mm	50 mm
A	16	24	180
В	16	24	130
c	3	5	-
d	15	12	120
m	8	12	50





Sensing Distance Feature Data by Parallel (Left / Right) Movement



6.0 4.0

2.0 2.0 2.0 2.0 150 100 50 00 50 100 150 200 250 Left ← Center → Right Sensing area Y (mm)